

DOCUMENT CODE
CP180-NSS-1114/5.1/2

Master S.r.l., declares that:

Center arm of art. Simple Plus 1114/5.1/2 is build with
Stainless Steel AISI430 and the article

Passed the test according to:

UNI EN 1670:2007

Building hardware - Corrosion resistance - Requirements and test methods

ISO 9227:2006

Corrosion tests in artificial atmosphere - Salt spray tests

Classification:

240 hour - Grade 4 - Very high corrosion resistance

Date of release: 14/09/2012

Maria Luigia Lacatena
Amministratore Unico MASTER srl

La presente dichiarazione è basata su specifiche di prova stabilite internamente da MASTER srl
MASTER srl si riserva il diritto di variare le caratteristiche tecniche dei suoi prodotti, senza preavviso ed in ogni momento.
Tutti i diritti sono riservati. E' fatto divieto di qualunque riproduzione parziale o totale dei presenti documenti.